

PWSID ME0090719

INDIAN TOWNSHIP TRIBAL WATER SYSTEM

2020 Consumer Confidence Report

General Information

Water System Contact Name: Indian Township Tribal Water System
Address: 410 Peter Dana Point Road
City, State, Zip Code: Indian Township, Maine 04668
Telephone #: 207-796-5263 Fax#: _____ Email: _____

Report Covering Calendar Year: Jan 1 - Dec 31, 2020

Upcoming Regularly Scheduled Meeting(s): Schedule Pending

Source Water Information

Description of Water Source: Wells: 4

Indian Township Tribal Water System obtains its water from four active bedrock wells, Well No. 3, 4, 5, and 6. Well No. 3 is 390 feet deep and was drilled in 1998 on Pit Road at Peter Dana Point. Well No. 4 is 360 feet deep and was drilled in 2001 on Pit Road at Peter Dana Point. Well No. 5 is 300 feet deep and was drilled in 2001 on the Hemlock Road at "The Strip". Well No. 6 is 440 feet deep and was drilled in 2007 on Hemlock Point at The Strip.

Water Treatment & Filtration Information:

Drinking water is treated using sodium hypochlorite for disinfection and fluoride for dental health. Well No. 3 and Well No. 4 enter treatment plant #2 on Pit Road at Peter Dana Point. Treatment plant # 3 is designed the same as treatment plant # 2. Well No. 5 and Well No. 6 enter into treatment plant #3 on Hemlock Road at The Strip. The treated water is stored in a 300,000-gallon storage tank and supplies water to 285 service connections, serving approximately 713 people.

Source Water Assessment:

The sources of drinking water include rivers, lakes, ponds, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material and can pick up substances resulting from human or animal activity. The Maine Drinking Water Program (DWP) has evaluated all public water supplies as part of the Source Water Assessment Program (SWAP). The assessments included geology, hydrology, land uses, water testing information, and the extent of land ownership or protection by local ordinance to see how likely our drinking water source is to being contaminated by human activities in the future. Assessment results are available at town offices and public water systems.

Definitions:

- Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water.
- Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health.
- Running Annual Average (RAA): A 12 month rolling average of all monthly or quarterly samples at all locations. Calculation of the RAA may contain data from the previous year.
- Locational Running Annual Average (LRAA): A 12 month rolling average of all monthly or quarterly samples at specific sampling locations. Calculation of the RAA may contain data from the previous year.
- Action Level (AL): The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.
- Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Units:

- ppm = parts per million or milligrams per liter (mg/L).
- ppb = parts per billion or micrograms per liter (µg/L).
- pCi/L = picocuries per liter (a measure of radioactivity).
- pos = positive samples.
- MFL = million fibers per liter

Water Test Results

Contaminant	Date	Results	MCL	MCLG	Possible Sources of Contamination
-------------	------	---------	-----	------	-----------------------------------

Microbiological

COLIFORM (TCR) (1)	2020	0 pos	1 pos/mo or 5%	0 pos	Naturally present in the environment.
--------------------	------	-------	----------------	-------	---------------------------------------

Inorganics

ARSENIC (6)	9/15/2020	3 ppb	10 ppb	0 ppb	Erosion of natural deposits. Runoff from orchards, glass and electronics production wastes.
BARIUM	9/15/2020	0.015 ppm	2 ppm	2 ppm	Discharge of drilling wastes. Discharge from metal refineries. Erosion of natural deposits.
FLUORIDE (3)	8/19/2020	1.18 ppm	4 ppm	4 ppm	Erosion of natural deposits. Water additive which promotes strong teeth. Discharge from fertilizer and aluminum factories.
NITRATE (5)	5/20/2020	0.06 ppm	10 ppm	10 ppm	Runoff from fertilizer use. Leaching from septic tanks, sewage. Erosion of natural deposits.

Radionuclides

COMBINED RADIUM (-226 & -228)	12/14/2018	0.8 pCi/l	5 pCi/l	0 pCi/l	Erosion of natural deposits.
COMBINED URANIUM	9/15/2020	4.2 ppb	30 ppb	0 ppb	Erosion of natural deposits.
GROSS ALPHA (7)	12/7/2020	9 pCi/l	15 pCi/l	0 pCi/l	Erosion of natural deposits.
RADIUM-226	12/14/2018	0.3 pCi/l	5 pCi/l	0 pCi/l	Erosion of natural deposits.
RADIUM-228	12/14/2018	0.5 pCi/l	5 pCi/l	0 pCi/l	Erosion of natural deposits.

Lead/Copper

COPPER 90TH% VALUE (4)	1/1/2018 - 12/31/2020	0.098 ppm	AL = 1.3 ppm	1.3 ppm	Corrosion of household plumbing systems.
LEAD 90TH% VALUE (4)	1/1/2018 - 12/31/2020	1.3 ppb	AL = 15 ppb	0 ppb	Corrosion of household plumbing systems.

Chlorine Residual (Add chlorine residual information)

CHLORINE RESIDUAL	Range (.02 - .25 ppm)	MRDL=4 ppm	MRDLG=4 ppm	By-product of drinking water chlorination.
-------------------	-----------------------	------------	-------------	--

Notes:

- 1) Total Coliform Bacteria: Reported as the highest monthly number of positive samples, for water systems that take less than 40 samples per month.
- 2) E. Coli: E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems.
- 3) Fluoride: For those systems that fluoridate, fluoride levels must be maintained between 0.5 to 1.2 ppm. The optimum level is 0.7 ppm.
- 4) Lead/Copper: Action levels (AL) are measured at consumer's tap. 90% of the tests must be equal to or below the action level.
- 5) Nitrate: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health provider.
- 6) Arsenic: While your drinking water may meet EPA's standard for Arsenic, if it contains between 5 to 10 ppb you should know that the standard balances the current understanding of arsenic's possible health effects against the costs of removing it from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems. Quarterly compliance is based on running annual average.
- 7) Gross Alpha: Action level over 5 pCi/L requires testing for Radium 226 and 228. Action level over 15 pCi/L requires testing for Uranium. Compliance is based on Gross Alpha results minus Uranium results = Net Gross Alpha.
- 8) Radon: The State of Maine adopted a Maximum Exposure Guideline (MEG) for Radon in drinking water at 4000 pCi/L, effective 1/1/07. If Radon exceeds the MEG in water, treatment is recommended. It is also advisable to test indoor air for Radon.
- 9) TTHM/HAA5: Total Trihalomethanes and Haloacetic Acids (TTHM and HAA5) are formed as a by-product of drinking water chlorination. This chemical reaction occurs when chlorine combines with naturally occurring organic matter in water. Compliance is based on running annual average.

All other regulated drinking water contaminants were below detection levels.

Secondary Contaminants (You are not required to list detects for secondary contaminants, but this information, particularly sodium levels, might be useful to your customers. The decision to supply this information in your CCR is up to you.)

IRON	0.08 ppm	9/15/2020
ZINC	0.019 ppm	9/15/2020
SULFATE	12 ppm	9/15/2020

SODIUM	8.9 ppm	9/15/2020
CHLORIDE	3 ppm	9/15/2020
MAGNESIUM	8.8 ppm	9/15/2020

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas stations, urban runoff, and septic systems.

Radioactive Contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791) or at the following link:

<https://www.epa.gov/ccr/forms/contact-us-about-consumer-confidence-reports>

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Indian Township Tribal Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at the following link:

<http://www.epa.gov/safewater/lead>

Violations

Violation Period	Violation Type
1/1/2020 - 12/31/2020	03 Violation - MONITORING, ROUTINE MAJOR CYANIDE TREAT PT 3
1/1/2012 - 12/31/2020	03 Violation - MONITORING, ROUTINE MAJOR ASBESTOS DIST SYS
1/1/2012 - 12/31/2020	03 Violation - MONITORING, ROUTINE MAJOR COMBINED RADIUM (-226 & -228) TREAT PT 3
1/1/2018 - 12/31/2020	27 Violation - MONITORING, ROUTINE (DBP), MAJOR TTHM/HAAC-STAGE 2 DIST SYS
1/1/2019 - 12/31/2019	71 Violation - CCR REPORT CONSUMER CONFIDENCE RULE

We are required to monitor our drinking water for specific contaminants on a regular basis. Results of regular monitoring indicate whether or not our drinking water meets health standards. During 2020, we did not test for, or failed to collect all necessary tests for radium, OR our results were not reported to the DWP on time (indicated as a Reporting violation above). To correct this issue, the testd were conducted in March 2021.

We are required to monitor our drinking water for specific contaminants on a regular basis. Results of regular monitoring indicate whether or not our drinking water meets health standards. During 2020, we did not test for, or failed to collect all necessary tests for Total Trihalomethanes (TTHM) and/or Haloacetic Acids (HAA5), OR our results were not reported to the DWP on time (indicated as a Reporting violation above). To correct this issue, the test was conducted in March 2021.

We are required to monitor our drinking water for specific contaminants on a regular basis. Results of regular monitoring indicate whether or not our drinking water meets health standards. During 2020, we did not test for, or failed to collect all necessary tests for cyanide, OR our results were not reported to the DWP on time (indicated as a Reporting violation above). To correct this issue, the test was conducted in March 2021.

We are required to monitor our drinking water for specific contaminants on a regular basis. Results of regular monitoring indicate whether or not our drinking water meets health standards. During 2020, we did not test for, or failed to collect all necessary tests for asbestos, OR our results were not reported to the DWP on time (indicated as a Reporting violation above). To correct this issue, the test was conducted in March 2021.

As a community public water system, we are required to provide a consumer confidence report to our customers on an annual basis. The consumer confidence report provides customers with information regarding the source and quality of the drinking water supplied to them as well as information on any violations that occurred during that time period. In 2019, we failed to distribute our consumer confidence report to our customers. To correct this issue, the 2019 CCR was made available in paper copy at the tribal offices and via online <https://www.passamaquoddy.com/wp-content/uploads/2019-CCR-For-Dispersal-and-Website.pdf>.

Waiver Information (to be included in the CCR for systems that were granted a waiver)

In 2020, our system was granted a 'Synthetic Organics Waiver.' This is a three year exemption from the monitoring/reporting requirements for the following industrial chemical(s): TOXAPHENE/CHLORDANE/PCB, HERBICIDES, CARBAMATE PESTICIDES, SEMIVOLATILE ORGANICS. This waiver was granted due to the absence of these potential sources of contamination within a half mile radius of the water source(s).